



**16th October 2006**

Renfrewshire Council  
South Building, Cotton Street  
PAISLEY  
PA1 1LL

**SCOTTISH WATER**

Planning & Development  
Services  
419 Balmore Road  
Glasgow  
G22 6NU

**CUSTOMER HELPLINE**

**T:** 0845 601 8855

**W:** [www.scottishwater.co.uk](http://www.scottishwater.co.uk)

**Dear Sir/Madam**

**PLANNING APPLICATION NUMBER : 06/1065/PP**

**DEVELOPMENT AT : Land at Intersection of M8 motorway/A8 Greenock Road,  
South of Craigmuir Farm and East of Bishopton  
Inchinnan**

**PROPOSAL : Construction of a motorway junction**

Scottish Water has no objections to this planning application. Please note that although Scottish Water has given approval at this stage, this does not guarantee a connection to Scottish Water's infrastructure. A separate application should be made for connection to our infrastructure after full planning has been granted.

A totally separate drainage system will be required with the surface water discharging to a suitable outlet. Scottish Water supports the principal of a sustainable urban drainage system (SUDS) and the developer should consider utilising this in the surface water drainage design. It is important to note that Scottish Water will not adopt surface water drainage systems that require the flows to be pumped.

This development may involve building over or in a such a way obstruct access to an existing public water main. Please contact Scottish Water, Asset Operations, Technical Support Team who will provide advice regarding possible solutions that will require to be implemented by the developer to protect our existing apparatus.

If the developer requires any further assistance or information on our response, please contact Chris McIntyre, Development Planner, on the above number or alternatively additional information is available on our website: [www.scottishwater.co.uk](http://www.scottishwater.co.uk).

Yours faithfully

**Fiona Hardie**  
**Planning and Development**